

FAUQUIER COUNTY  
**WATER & SANITATION AUTHORITY**  
7172 Kennedy Road • Vint Hill Farms  
Warrenton, Virginia 20187-3907  
Phone (540) 349-2092 • Fax (540) 347-7689



## UTILITY STANDARDS MANUAL AMENDMENT FORM

The Authority's Utility Standards Manual is hereby amended as follows:

### Section Being Amended:

#### 5.01 Pipe Materials

### From:

#### 5.01 Pipe Materials


The following pipe materials are approved for use in systems to be owned by the Authority.

### To:

#### 5.01 Pipe Materials

The following pipe materials are approved for use in water systems to be owned by the Authority. Except as otherwise restricted in this document, water lines between 4" and 12" in diameter may be PVCO. Water lines greater than 12" diameter must be Ductile Iron Pipe (DIP).

Approved:

  
Barney E. Durrett, Jr.  
General Manager

1/29/09  
Date