

FAUQUIER COUNTY
WATER & SANITATION AUTHORITY
7172 Kennedy Road • Vint Hill Farms
Warrenton, Virginia 20187-3907
Phone (540) 349-2092 • Fax (540) 347-7689



UTILITY STANDARDS MANUAL AMENDMENT FORM

The Authority's Utility Standards Manual is hereby amended as follows:

Section Being Amended:

5.01.A Pipe Materials – Ductile Iron Standard Mechanical Joint Pipe

From:

- A. Ductile Iron Standard Mechanical Joint Pipe - Ductile iron standard mechanical joint pipe shall conform to ANSI/AWWA C151/A21.51 or latest revision and shall be double-lined with cement mortar, seal coated and have a protective exterior coating. Thickness class shall be minimum Class 50. A greater thickness class may be required when conditions so dictate. Polyethylene encasement, in accordance with ANSI A21.5 (AWWA C105) may be required under certain soil conditions.

To:

- A. Ductile Iron Standard Mechanical Joint Pipe - Ductile iron standard mechanical joint pipe shall conform to ANSI/AWWA C151/A21.51 or latest revision and shall be double-lined with cement mortar, seal coated and have a protective exterior coating. Thickness class shall be minimum Class 52. A greater thickness class may be required when conditions so dictate. Polyethylene encasement, in accordance with ANSI A21.5 (AWWA C105) may be required under certain soil conditions.

Approved:


Barney E. Durrett, Jr.
General Manager

1/29/09
Date