

FAUQUIER COUNTY
WATER & SANITATION AUTHORITY
7172 Kennedy Road • Vint Hill Farms
Warrenton, Virginia 20187-3907
Phone (540) 349-2092 • Fax (540) 347-7689



UTILITY STANDARDS MANUAL AMENDMENT FORM

The Authority's Utility Standards Manual is hereby amended as follows:

Section Being Amended:

5.01.F Pipe Materials – Polyvinyl Chloride Pipe


From:

- F. Polyvinyl Chloride Pipe - PVC pipe shall conform to AWWA C900 and shall be minimum DR18 for Class 150 pipe and DR14 for Class 200 pipe. Pipe shall be clearly marked to show class, size, manufacturer's name, and NSF-PW symbol. Fittings for PVC pipe shall be mechanical joint ductile iron.

To:

- F. Polyvinyl Chloride (PVC) Pipe – All PVC water pipe between 4” and 12” diameter shall be molecularly oriented polyvinyl chloride (PVCO) pressure pipe and shall conform to AWWA Standard C909, and be minimum Pressure Class 200. Wall thickness and Outside Diameter shall be as indicated in Table 1 of AWWA Standard C909.

Approved:


Barney E. Durrett, Jr.
General Manager

1/29/09
Date