

FAUQUIER COUNTY

WATER & SANITATION AUTHORITY

7172 Kennedy Road • Vint Hill Farms

Warrenton, Virginia 20187-3907

Phone (540) 349-2092 • Fax (540) 347-7689



UTILITY STANDARDS MANUAL AMENDMENT FORM

The Authority's Utility Standards Manual is hereby amended as follows:

Section Being Amended: Section 5.11 – Water Meters
(Number and Nomenclature)

From:

The size and type of all water meters shall be determined by the General Manager based the proposed use. All water meters, including Fire Service Meters, shall be equipped with a remote read register and sensor compatible with the Authority's existing touch read system.

Positive displacement meters shall meet AWWA – C700, latest revision "Standard Specifications for Cold Water Meters", and shall Neptune Model T-10 as manufactured by Schlumberger Industries, or approved equal.

Turbine type meters shall meet AWWA – C701, latest revision, and shall be Neptune HP Turbine Type, as manufactured by Schlumberger Industries, or approved equal.

All meters greater than 5/8" x 3/4" in size shall be provided by the property owner or contractor.

To:

The size and type of all water meters shall be determined by the General Manager based on fixture count and the proposed use(s).

All water meters shall be equipped with a Radio Frequency Meter Interface Unit (MIU) appropriate to the type of meter specified and as manufactured by Neptune Technology Group, Inc. and compatible with the Authority's radio read system.


Positive displacement meters shall meet AWWA – C700, latest revision "Standard Specifications for Cold Water Meters", and shall be a Model T-10, as manufactured by Neptune Technology Group, Inc.

Turbine type meters shall meet AWWA – C701, latest revision, and shall be a Model HP Turbine, as manufactured by Neptune Technology Group, Inc.

Compound type meters shall meet AWWA C702, latest revision, and shall be a Model Tru/Flo Compound, as manufactured by Neptune Technology Group, Inc.

All meters greater than Full 3/4" in size shall be provided by the property owner or his contractor.

Approved:


Barney E. Durrett, Jr.
General Manager

2/14/08
Date