

GENERAL NOTES: WATERLINE CONSTRUCTION

1. All waterline construction shall conform to the Fauquier County Water and Sanitation Authority's utility standards.
2. The contractor must attend a mandatory pre-construction meeting with the FCWSA prior to the start of construction.
3. Waterline inspections and testing must be scheduled a minimum of 48 hours in advance with the FCWSA Inspector.
4. Water service lines crossing underneath pavement must be installed in a 2-inch schedule 40 PVC casing pipe.
5. Water mains are to be constructed of AWWA C-900 PVC or Class 52 cement lined Ductile Iron water pipe.
6. Water service lines are to be constructed of SDR-9, 200 PSI, Polyethylene pipe.
7. Compaction requirements for waterline construction are to be the same as those required for sewer construction.
8. Water service lines located on private property are to be maintained by the property owner.